


Email notification



Federal Express 8996 1811 1852

April 30, 2014

Ms. Ingrid H. Hopkins
Water Protection Division (3WP42)
US EPA – Region III
1650 Arch Street
Philadelphia, PA 19103-3029
(215) 814-5437
hopkins.ingrid@epa.gov



**RE: Benning Road Generating Station – NPDES Permit No. DC 0000094
Re-sample for pH at Outfall 101**

Dear Ms. Hopkins,

This letter is a follow-up to our April 21, 2014 letter, in which it was indicated that we will re-test Outfall 101 during the next qualifying storm event to assess whether elevated pH conditions are persisting.

On April 28, 2014 at approximately 19:15, a composite pH sample was taken from Outfall 101 during a qualifying storm event. The reading indicated a pH value of 7.9, which is in compliance with the permit limit of 6 – 8.5. This result indicates that elevated pH conditions are not persisting.

Please contact me at (703) 253-1787 or by electronic mail at mwilliams@pepcoenergy.com if you need additional information.

Respectfully yours,

A handwritten signature in blue ink that reads "Michael V. Williams".

**Michael V. Williams
Power Plant Asset Manager
Pepco Energy Services, Inc.**

Cc: File